

Product fiche concerning the COMMISSION DELEGATED REGULATIONS

(EU)No 811/2013 of 18 February 2013

(EU)No 813/2013 of 2 August 2013

Air Source Heat Pumps

Grant Engineering (UK) Ltd
Hopton House, Hopton Industrial Estate, Devizes, Wiltshire, SN10 2EU
t: +44 (0)1380 736920 f: +44 (0)1380 736991
e: info@grantuk.com w: www.grantuk.com



Models:	Outdoor Unit:	Aerona ³ HPID10
	Indoor Unit:	None
Air-to-water heat pump		Yes
Brine-to-water heat pump		No
Low temperature heat pump		No
Equipped with a supplementary heater		No
Heat Pump Combination Heater		Yes
Parameters shall be declared for		low-temperature applications
Parameters shall be declared for		Average Climate Conditions

Item	Symbol	Value	Unit	Item	Symbol	Value	Unit
Rated Heat Output (*)	Prated	7.5	kW	Seasonal space heating energy efficiency	η_s	174	%

Declared capacity for heating for part load at indoor Temperature 20°C and outdoor temperature Tj

Declared coefficient of performance or primary energy ratio for part load at indoor temperature 20°C and outdoor temperature Tj

Tj = -10°C	Pdh	7.5	kW	Tj = -10°C	COPd	2.35	
Degradation co-efficient (**)	Cdh	0.99	-				
Tj = -7°C	Pdh	6.74	kW	Tj = -7°C	COPd	2.65	
Degradation co-efficient (**)	Cdh	0.99	-				
Tj = +2°C	Pdh	4.15	kW	Tj = +2°C	COPd	4.52	
Degradation co-efficient (**)	Cdh	0.99	-				
Tj = +7°C	Pdh	3.02	kW	Tj = +7°C	COPd	5.89	
Degradation co-efficient (**)	Cdh	0.98	-				
Tj = +12°C	Pdh	4.70	kW	Tj = +12°C	COPd	6.35	
Degradation co-efficient (**)	Cdh	0.99	-				
Tj = bivalent temperature	Pdh	7.50	kW	Tj = bivalent temperature	COPd	2.35	
Tj = operation limit temperature	Pdh	7.50	kW	Tj = operation limit temperature	COPd	2.35	
Tj = -15°C (if TOL < -20°C)	Pdh	-	kW	Tj = -15°C (if TOL < -20°C)	COPd	-	
Bivalent temperature	Tbiv	-10		Operation limit temperature	TOL	-10	°C
				Heating water operating limit temperature	WTOL	60	°C

Power consumption in modes other than active mode

Supplementary Heater

Off Mode	P _{OFF}	0.01	kW	Rate heat output	P _{sup}	0.00	kW
Thermostat-off mode	P _{TO}	0.04	kW				
Standby mode	P _{SB}	0.01	kW	Type of energy input			
Crankcase heater mode	P _{CK}	0.00	kW				

Other items

Capacity control	Variable			Rated airflow rate, outdoors	-	2664	m ³ /h
Sound power level	L _{WA}	44/65	dBA				
indoors/outdoors							
Annual Energy consumption	Q _{HE}	3318	kWh				

For heat pump combination heater

Water heating energy efficiency

Declared load profile	-	-	-	η_{wh}	-		%
Daily electricity consumption	Q _{elec}	-	kWh/h				
Annual electricity consumption	AEC	-	kWh/h				

Contact Details:

Grant Engineering (UK) Ltd, Hopton House, Devizes, SN10 2EU

(*) For heat pumps space heaters and heat pump combination heaters, the rated heat output Prated is equal to the design load for heating



Pdesignh, and the rated heat output of a supplementary heater Psup is equal to the supplementary capacity for heating sup(Tj).
 (**) If Cdh is not determined by measurement then the default degradation coefficient is Cdh = 0.9.

Models:	Outdoor Unit:	Aerona³ HPID10
	Indoor Unit:	None
Air-to-water heat pump		Yes
Brine-to-water heat pump		No
Low temperature heat pump		No
Equipped with a supplementary heater		No
Heat Pump Combination Heater		Yes
Parameters shall be declared for		Medium-temperature applications
Parameters shall be declared for		Average Climate Conditions

Item	Symbol	Value	Unit	Item	Symbol	Value	Unit
Rated Heat Output (*)	Prated	7.5	kW	Seasonal space heating energy efficiency	η_s	126	%
Declared capacity for heating for part load at indoor Temperature 20°C and outdoor temperature Tj				Declared coefficient of performance or primary energy ratio for part load at indoor temperature 20°C and outdoor temperature Tj			
Tj = -10°C	Pdh	6.9	kW	Tj = -10°C	COPd	1.63	
Degradation co-efficient (**)	Cdh	0.99	-				
Tj = -7°C	Pdh	6.68	kW	Tj = -7°C	COPd	1.91	
Degradation co-efficient (**)	Cdh	0.99	-				
Tj = +2°C	Pdh	4.01	kW	Tj = +2°C	COPd	3.09	
Degradation co-efficient (**)	Cdh	0.99	-				
Tj = +7°C	Pdh	2.80	kW	Tj = +7°C	COPd	4.51	
Degradation co-efficient (**)	Cdh	0.98	-				
Tj = +12°C	Pdh	4.30	kW	Tj = +12°C	COPd	6.71	
Degradation co-efficient (**)	Cdh	0.99	-				
Tj = bivalent temperature	Pdh	6.68	kW	Tj = bivalent temperature	COPd	1.91	
Tj = operation limit temperature	Pdh	6.90	kW	Tj = operation limit temperature	COPd	1.63	
Tj = -15°C (if TOL < -20°C)	Pdh	-	kW	Tj = -15°C (if TOL < -20°C)	COPd	-	
Bivalent temperature	Tbiv	-7	°C	Operation limit temperature	TOL	-10	°C
				Heating water operating limit temperature	WTOL	60	°C
Power consumption in modes other than active mode				Supplementary Heater			
Off Mode	P _{OFF}	0.01	kW	Rate heat output	P _{sup}	0.6	kW
Thermostat-off mode	P _{TO}	0.04	kW				
Standby mode	P _{SB}	0.01	kW	Type of energy input			
Crankcase heater mode	P _{CK}	0.00	kW				
Other items							
Capacity control	Variable			Rated airflow rate, outdoors	-	2664	m³/h
Sound power level	L _{WA}	46/67	dBA				
indoors/outdoors							
Annual Energy consumption	Q _{HE}	4762	kWh				
For heat pump combination heater				Water heating energy efficiency			
Declared load profile	-	-	-		η_{wh}	-	%
Daily electricity consumption	Q _{elec}	-	kWh				
Annual electricity consumption	AEC	-	kWh				

Contact Details: Grant Engineering (UK) Ltd, Hopton House, Devizes, SN10 2EU



(*) For heat pumps space heaters and heat pump combination heaters, the rated heat output P_{rated} is equal to the design load for heating $P_{designh}$, and the rated heat output of a supplementary heater P_{sup} is equal to the supplementary capacity for heating $sup(T_j)$.
(**) If C_{dh} is not determined by measurement then the default degradation coefficient is $C_{dh} = 0.9$.

End of Life Information – Air Source Heat Pumps

General

Grant air source heat pumps incorporate components manufactured from a variety of different materials. However, most of these materials cannot be recycled as they are contaminated by the refrigerant and oil used in the heat pump.

Disassembly

This product may only be disassembled by a suitably qualified (F-gas) refrigeration engineer.

Under no circumstances should the refrigerant be released into the atmosphere.

Recycling

In order for the heat pump to be recycled or disposed of it must be taken to a suitably licensed waste facility. You will need to contact a qualified refrigeration engineer to do this for you.

Disposal

The refrigerant will be removed and returned to the refrigerant manufacturer for recycling or disposal.

The complete heat pump unit, including the compressor and the oil contained within it, must be disposed of at a licensed waste facility, as it still remains contaminated by the refrigerant.



Neil Sawers
Technical Manager